

## Pasco County Utilities Emergency Rule Notification

- Installation Name: **Wesley Center Wastewater Treatment Facility**
- Installation Address:
- For further information, contact James Hircock, Environmental Compliance Specialist,  
727-457-0358 (Cell) or 813-247-0391 (PTT)
- Permit Number (if applicable): **FLA016094**
- Date and time of the incident or discovery: **DATE: 9 February 2018 TIME: 1:50 PM**
- Location of the incident or discovery: **Chancey Road, Wesley Chapel**
- Suspected source and cause of incident or discovery: **ARV TR-455-arv-3 clogged with liquids in green structure causing spill.**
- Type of pollution, including substance or contaminant name(s): **Untreated Domestic Waste**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 50 Gallons of Untreated Domestic Waste (50 Gallons recovered)**
- Source: (e.g. land, water, air) affected: **LAND:   X   WATER: \_\_\_\_\_ AIR: \_\_\_\_\_**
- potentially affected areas beyond installation property boundary: **NONE, lime and clean water used to neutralize the impacted area.**
- Potential risk (public health, safety, or welfare): **High \_\_\_\_\_ Medium \_\_\_\_\_ Low \_\_\_\_\_ None   X**
- Identification of other parties notified of incident and time notification occurred:
  - Name: **(FDEP) Ileana Hernandez** Time Notified: **(24 Hour) X (48 Hour)**
  - Name: **(Daniel Biles, P.E.)** Time Notified: **(24 Hour) (48 Hour)**
  - Name: **(Tambrey Laine)** Time Notified: **(24 Hour) (48 Hour)**
  - Name: **(Flip Mellinger)** Time Notified: **(24 Hour) (48 Hour)**
  - Name: **(Mike Wells - Chairman)** Time Notified: **(24 Hour) (48 Hour)**
  - Name: **(ALL Directors) Rob Marin** Time Notified: **(24 Hour) X (48 Hour)**
- Additional information that may be helpful: **MAP # 455, SSO # 895. NO further action needed. ARV was cleaned and put back into service.**