

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Shady Hills Wastewater Treatment Facility**
- Installation Address: **14220 Hays Road, Spring Hill, FL 34610**
- For further information, contact James Hircock, Environmental Compliance Specialist,
727-457-0358 (Cell) or 727-247-0391 (PTT)
- Permit Number (if applicable): **FLA012741**
- Date and time of the incident or discovery: **DATE: 7 January 2018 TIME: 12:30 AM**
- Location of the incident or discovery: **8509 Huntsman Drive (Bear Creek Sub-Division)**
- Suspected source and cause of incident or discovery: **M/H # 191 spilling from blockage..**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 50 gallons of untreated domestic waste (50 gallons recovered). Used 300 gallons water and 2 pounds lime to neutralize the site.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: _____ AIR: _____**
- potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High _____ Medium _____ Low _____ None X**
- Identification of other parties notified of incident and time notification occurred:
 - Name: (FDEP) Ileana Hernandez Time Notified: (24 Hour) X (48 Hour)**
 - Name: (Daniel Biles, P.E.) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Tambrey Laine) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Flip Mellinger) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Mike Wells-BOCC Chairman) Time Notified: (24 Hour) (48 Hour)**
 - Name: (ALL Directors) Rob Marin Time Notified: (24 Hour) X (48 Hour)**
- Additional information that may be helpful: **MAP # 86, SSO # 888, W.O. # 616935. Jetted from upstream M/H #190 to break up blockage. NO further action.**