

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Land O'Lakes Wastewater Treatment Facility**
- Installation Address: **6003 Parkway Boulevard, Land O'Lakes, FL 34639**
- For further information, contact James Hircock, Environmental Compliance Specialist,
727-457-0358 (Cell) or 727-247-0391 (PTT)
- Permit Number (if applicable): **FLA012731**
- Date and time of the incident or discovery: **DATE: 4 March 2018 TIME: 9:00 AM**
- Location of the incident or discovery: **Sunlake Blvd. And Lake Patience Road**
- Suspected source and cause of incident or discovery: **Clamp came loose from the bypass system that was set up by United Rental Services connections of the bower pipe system.**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 37,000 gallons of untreated domestic waste (54,000 gallons recovered). Used water and 48 Bags (1900 pounds) of lime to neutralize the site**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: _____ AIR: _____**
- potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High _____ Medium _____ Low _____ None X**
- Identification of other parties notified of incident and time notification occurred:
 - Name: (FDEP) Ileana Hernandez Time Notified: (24 Hour) X (48 Hour)**
 - Name: (Daniel Biles, P.E.) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Tambrey Laine) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Flip Mellinger) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Mike Wells-BOCC Chairman) Time Notified: (24 Hour) (48 Hour)**
 - Name: (ALL Directors) Rob Marin Time Notified: (24 Hour) X (48 Hour)**
- Additional information that may be helpful: **MAP # 292, SSO # 899, Cotter pins installed on pipe clamps to avoid coming loose again. NO further action.**