

Pasco County Utilities Emergency Rule Notification

- Installation Name: **Shady Hills Wastewater Treatment Facility**
- Installation Address: **14220 Hays Road, Spring Hill, FL 34610**
- For further information, contact James Hircock, Environmental Compliance Specialist,
727-457-0358 (Cell) or 727-247-0391 (PTT)
- Permit Number (if applicable): **FLA012741**
- Date and time of the incident or discovery: **DATE: 6 November 2017 TIME: 1:30 PM**
- Location of the incident or discovery: **9330 SR 54 Trinity Medical Hospital**
- Suspected source and cause of incident or discovery: **TR-112-ARV-01 was leaking. flapper in the head of the ARV had disintegrated causing the spill.**
- Type of pollution, including substance or contaminant name(s): **Untreated domestic waste.**
- Estimate amount of pollution, including substance or contaminant name(s): **Approximately 20,500 gallons of untreated domestic waste (20,500 gallons recovered). Pulled 15,500 gallons from retention pond and used 200 pounds lime to neutralize the site.**
- Source: (e.g. land, water, air) affected: **LAND: X WATER: _____ AIR: _____**
- potentially affected areas beyond installation property boundary: **NONE**
- Potential risk (public health, safety, or welfare): **High _____ Medium _____ Low _____ None X**
- Identification of other parties notified of incident and time notification occurred:
 - Name: (FDEP) Ileana Hernandez Time Notified: (24 Hour) X (48 Hour)**
 - Name: (Daniel Biles, P.E.) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Tambrey Laine) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Flip Mellinger) Time Notified: (24 Hour) (48 Hour)**
 - Name: (Mike Moore–BOCC Chairman) Time Notified: (24 Hour) (48 Hour)**
 - Name: (ALL Directors) Rob Marin Time Notified: (24 Hour) X (48 Hour)**
- Additional information that may be helpful: **MAP # 112, SSO # 876, W.O. # 599378, Pulled samples from retention pond. Repair has been completed. NO further action.**